



Town of Clover
Development Services
114 Bethel Street, PO Box 1060
Clover, South Carolina 29710
Ph: 803-222-9495 / Fax: 803-222-6955

CODE INTERPRETATION

QUESTION

What are the requirements for disconnects for water heaters or HVAC equipment?

CODE REFERENCE:

Clover Policy

ANSWER

For safety reasons, we encourage the installation of disconnects wherever required.

If a new service only is installed and no new wiring is run to the appliance and the controlling panel is not replaced, then the requirement for a disconnect will not be enforced at the panel board or the appliance.

Replacement of breakers controlling the appliance at the panel will require a means of disconnect either at the panel or at the appliance.

If a panel controlling the appliance is replaced, then a method of disconnect (at the appliance or a lock-out at the panel) is required.

If the appliance is changed out as part of the work, then a method of disconnect (at the appliance or a lock-out at the panel) is required.

A handwritten signature in black ink that reads "Joe Hunderbuck Jr." The signature is written in a cursive, flowing style.

Building Official / Town of Clover

Date: May 24, 2012