



TOWN OF CLOVER

The town with "love" in the middle



To All Clover Festival Attendees:

All vendors are reminded that there must be a minimum of three (3) feet of clearance on both sides of fire hydrants for a total of not less than six (6) feet of clearance around all hydrants.

All food vendors who prepare on-site any item for consumption will be inspected. Also, all vendors will be inspected for the following code requirements. These requirements must be met before they will be allowed to operate.

- **Fire Code IFC 904.11.5 & 906:** All food vendors utilizing cooking equipment involving vegetable or animal oils shall be protected by a Class (K) rated portable extinguisher. All other vendors shall have a minimum of one (1) 5 lb. ABC fire extinguisher.
- **Fire Code IFC 3003.10:** All gas cylinders shall be maintained in good order. No rusted tanks will be allowed to be used.
- **Fire Code IFC 3003.3.3.3.3:** All gas cylinders in use or in storage shall be secured at all times to prevent them from falling or being knocked over. Also, cylinders must have an approved shut off valve.
- **Fire Code IFC 38:** All gas lines shall be in good shape; cracked lines and any other non-conformity will not be allowed.
- **Fire Code IFC 2404.2:** Any tent or temporary membrane structure over any cooking appliance shall meet NFPA 701 or be treated with a flame retardant chemical and shall have a minimum distance of 18" from any combustible material. All other vendors using vendor trailers for cooking must have an approved hood system venting to the outside.
- **National Electric Code:** Extension cords shall be free of taped up splices and in good condition. Cords shall be installed and/or protected so as to not be a tripping hazard to the public. All outdoor receptacles must be in a weather proof type box with cover and approved plug and cord connector.

Sincerely,

Luke Caldwell
Codes/Building Inspector
Town of Clover
803-222-5158
