



Town of Clover
Development Services
114 Bethel Street, PO Box 1060
Clover, South Carolina 29710
Ph: 803-222-9495 / Fax: 803-222-6955

CODE INTERPRETATION

QUESTION

Is a drip edge required on a house roof?

CODE REFERENCE:

None

ANSWER

If the roof covering manufacturer's installation instructions call for a drip edge, then a drip edge is required. Otherwise, there is no specific code in the IRC which requires a drip edge.

A drip edge is *recommended* however, and drip edges are often integrated into metal fascia coverings.

A handwritten signature in black ink, reading "Joe Hunderbuck Jr." in a cursive style.

Building Official / Town of Clover

Date: May 31, 2011