



Town of Clover
Development Services
114 Bethel Street, PO Box 1060
Clover, South Carolina 29710
Ph: 803-222-9495 / Fax: 803-222-6955

CODE INTERPRETATION

QUESTION

What are the electrical requirements when it comes to the location and accessibility of panelboards?

CODE REFERENCE:

2006 International Residential E3305.5 & Clover Policy

ANSWER

Panelboards (main and sub-panels) with branch circuit overcurrent protection shall be accessible. They will only be allowed in attics with permanent stairs or in crawl spaces with standard (6' tall) doors.

Where ever they are placed, the other Code requirements regarding clear working space and illumination shall apply.

Building Official / Town of Clover

Date: February 3, 2011